

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0476:139

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Harrington Signal Inc., 2519 4<sup>th</sup> Ave., Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

**DESIGN:** Model HSG015-24VWR and HSG015-24VWW horn strobes; suffix WR (wall mount, red) and WW (wall mount, white). Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 24 VDC  
Candela: 15cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as audible/visual appliance for use with separately listed compatible fire alarm control units. For indoor use only.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to listee's Installation Instructions Manual for details.

**XLf:** 7135-0569:122



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 3, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy  
Program Manager